

Office of the District Fire Officer  
Karnataka State Fire  
and Emergency Services  
Khanapur Road, Belagavi-590001



Phone : 0831-2429441  
E-Mail : dfobgv@gmail.com

C.NO/172/NOC/DFO/BELAGAVI/2023

Date :22-11-2023

To,  
The Principal,  
KLE Mahadevappanna Munavalli  
School, Gokak, Gokak Taluk,  
Belagavi District.

Sir,

Sub : Issuing of 'NOC' to KLE Mahadevappanna Munavalli School, Gokak, Gokak Taluk,  
Belagavi District.

Ref : 1) C.NO/172/ADV/DFO/BELAGAVI/2023 Date: 29-08-2023.

2) Applicant Request Letter Date: 22/06/2023.

\*\_\*\_\*\_\*\_\*\_\*\_\*\_\*\_\*\_\*

With reference to the subject above cited, the premises of **KLE Mahadevappanna Munavalli School**, building consisting with Ground & 3 Upper floors situated at **Gokak, Gokak Taluk, Belagavi District** was inspected by District Fire Office Belagavi on 28-10-2023 with respect to fire Prevention, Fire fighting and Evacuation measures complied in the above premises for issuing of NOC & the details as under.

**ANNEXURE-1**

**"GROUP-B Educational Buildings**

**NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.**

**(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)**

**A. Details of the Building/Premises.**

**B.**

01	Name and Address of the Applicant	The Principal, KLE Mahadevappanna Munavalli School, Gokak, Gokak Taluk, Belagavi District.
02	Name and Address of the Premises	KLE Mahadevappanna Munavalli School, Gokak, Gokak Taluk, Belagavi District.
03.	Name and Address of the Building Owner	The President KLE Society, Belagavi.
04.	Number of Building	01
05.	Number of Floors	Ground & 3 Upper Floors
06.	<b>Floor-wise details of Occupancy:-</b>	
	Ground Floor	Principal Chamber-01, Office-01, Art Room-01, NCC Room-01, Reading Room-01, Class Room-08, Staff Room-01, Physics Lab-01, Co-Ordinators Room-01, Scouts & Guides Room-01.
	1 <sup>st</sup> Floor	Class Room-08
	2 <sup>nd</sup> Floor	Class Room-08 & Science Lab-01.
	3 <sup>rd</sup> Floor	Class Room-08, Computer Lab-02, Library-01, Tabola Room-01, Class Room-06, Function hall-01, Class room- 07, Examination hall-01 & Staff room-01.



07.	Height of the building	14.85 mtr
08.	Site area	
09.	<b>Built-up area of each floor:-</b>	
	Ground Floor	12000.94 Sq ft
	1 <sup>st</sup> Floor	15766.63 Sq ft
	2 <sup>nd</sup> Floor	16990.97 Sq ft
	3 <sup>rd</sup> Floor	10349.42 Sq ft
		<b>55,107.96 Sq ft</b>
10.	<b>Total Built-up area</b>	
11.	<b>Surrounding properties:-</b>	
	East	KLE Hospital
	West	Residential Building
	North	Valmiki Temple
	South	Road
12.	<b>Open Space all around the building</b>	
	East	80.00 mtr
	West	Nil
	North	Nil
	South	Nil
<b>Allowed Setbacks ( open space) should be maintained free from further obstruction/construction.</b>		

**B.On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-**

Sl. No	Details (02)	Existing (03)	Recommendations (04)												
01.	Accessibility to the premises	Accessibility from Southern side with 10.00 Mtr wide road	Adequate												
02.	Number of Entrances	01 entrance of 07.20 mtr wide.	Adequate												
03.	Number of Staircase	<table border="1"> <tr> <td>No of staircase</td> <td>01 nos.</td> </tr> <tr> <td>Width of the staircase</td> <td>02.00 mtr</td> </tr> <tr> <td>Width of threads</td> <td>0.30 mtr</td> </tr> <tr> <td>Height of risers</td> <td>0.15 mtr</td> </tr> <tr> <td>No of risers per flight</td> <td>11</td> </tr> <tr> <td>Height of the hand drill.</td> <td>01.00 mtr</td> </tr> </table>	No of staircase	01 nos.	Width of the staircase	02.00 mtr	Width of threads	0.30 mtr	Height of risers	0.15 mtr	No of risers per flight	11	Height of the hand drill.	01.00 mtr	Complied
No of staircase	01 nos.														
Width of the staircase	02.00 mtr														
Width of threads	0.30 mtr														
Height of risers	0.15 mtr														
No of risers per flight	11														
Height of the hand drill.	01.00 mtr														
04.	Portable Extinguishers	<p>13 Nos. of 6 Kg Capacity ABC type &amp; 01 no. of 4.5 Kg capacity CO<sub>2</sub> type Fire Extinguisher &amp; 03 nos. of water type extinguishers has been provided.</p> <p>All the extinguishers suggested are BIS markings and are located at an easily accessible position without obstructing the normal passage.</p>	Complied												
05.	Hose reel hose system	04 nos. of hose reel hose has been provided. The hose reel hose of min 19 mm size and of 30 mtrs length has been provided to reach the farthest point of each floor and shut off branch having a nozzle of 05 mm size.	Complied												
06.	At the terrace tank level with minimum pressure of 3.5 kg/cm <sup>2</sup>	The system has been connected to booster pump of 450 LPM capacity has been provided. Further the system also has been connected to alternative source of power supply.	Complied												





07.	Diesel Generator	02 nos. of 200 & 130 KVA capacity generator has been provided	Complied
08.	Terrace Tank	07 nos. of 2000 ltrs & 01no of 1000 ltrs capacity overhead water tank has been provided.	Complied
09.	Escape routes	Direction in which the students/teachers have to move in the event of emergency have been indicated in the corridor/passage as a guide during evacuation.	Complied.
10.	Fire Order ( Fire safety plans)	A notice board indicating the action to be taken by the employees in case of any emergency have been displayed along with the telephone numbers of Gokak Fire station i.e 08332-225011, 101 & 080-22971550, 22971500, 22971600 the telephone nos nearest ambulance services and police station.	Complied
11.	No Smoking board	COPTA Sec-4 direction of No Smoking area, smoking here is an offence board is written in the English & Kannada both languages and is displayed inside the entry/exit of the each floor.	Complied
12.	Fire Siren	A fire siren has been installed in the premises to inform the students/teachers in case of a fire emergency and evacuate the area.	Complied
13.	Nominate One Fire Nodal Officer	Smt. Nanda Chunamari, Smt. Ushakiran Guddadamani & Smt. Drakshayani Chandargi are has been nominated as fire nodal officers.	Complied
14.	Fire Fighting Training	Not Imparted	At least 40% of the Teaching and non Teaching staff should be got trained in basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre.
15.	<p><b><u>Fire Precautionary Measures</u></b></p> <p>A:- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises.</p> <p>B:- Accumulation of combustibile waste in and around the premises should be avoided.</p> <p>C:- The Exit ways shall be always kept clear without any obstruction.</p> <p>D:- Liquefied petroleum gas should not be stored in the building.</p> <p>E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction.</p> <p>F:- During the class hours the class room door shall not be locked from inside to out side.</p> <p>G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14<sup>th</sup> of every year by conducting Fire Safety drills with co-ordination with the fire services department.</p>		

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "NOC" to "KLE Mahadevappa Munavalli School" Gokak, Gokak Taluk, Belagavi District. As they have complied all the recommendations as per reference 1. With the condition that the staff should get trained in the basic fire fighting at Training Centre R.A. Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre Hubballi.

This "NOC" is valid for only one year from the date of issue and is renewable.  
is renewable.

Yours Faithfully

  
District Fire Officer 27/11/2023  
Karnataka State Fire And Emergency Services  
Belagavi-01.